

FAILURE ANALYSIS

A Guide to Analyzing Axial Piston Pump Failures

Typical Failure Modes

- Contamination
- Fluid Issue
- Over Pressurization
- Improper Inlet Condition
- Case To Inlet Differential
- Miscellaneous

CONTAMINATION

**10 Micron, Beta 10 of 4 or Better
ISO Contamination Grade of 21/19/16**

- PISTON SEIZED IN BORE, PULLS SHOE OFF
- PISTONS SHOW FINE SCRATCHES, DULL FINISH
- EXCESSIVE WEAR ON SWASHBLOCK FACE, SHOE FACE AND VALVE PLATE FACE
- EXCESSIVE WEAR ON SADDLE BEARINGS
- HYDRO-DYNAMIC BEARING WORN
- CONTROL UNSTABLE: PISTON STICKING, COMPENSATOR SPOOL STUCK OR WORN, ORIFICE IN CONTROL PISTON PLUGGED

PISTON THAT SEIZED IN BORE


Note Metal
Transfer






VERTICAL SCRATCHES: A Clear Indication of Contamination

Oilgear



Innovative Fluid Power

DULL AND SCRATCHY FINISH




Normal Appearance:
A Mirror Finish

Abnormal Appearance:
A Steel Wool Look

Oilgear

SHOE WEAR PLATE SHOWING SIGNS OF WEAR DUE TO DIRT

Scratchy Uneven
Wear



Innovative Fluid Power

The text 'Fluid Issue' is centered at the top of the slide in a bold, black font. In the top left corner, there is a circular inset image showing a close-up of industrial machinery, possibly a hydraulic pump or valve, with a blue curved graphic element overlapping it.

Fluid Issue

Viscosity too Low, Operating Temperature too High, Not a Hydraulic Fluid, Fluid Breaking Down

- PISTON SEIZED IN BORE, PULLS PISTON SHOE
- SHOE FACES AND OR VALVE PLATE FACE SMEARED
- BALL WORN THROUGH SHOE RETAINER
- SHAFT SEAL LEAKS
- CAVITATION, AIR ENTRAINMENT
- EXCESSIVE SADDLE BEARING WEAR



Oilgear

VALVE PLATE RUN ON A BAD FLUID

Note the
Smeared
Running
Surface

Innovative Fluid Power



Oilgear

WORN FULCRUM BALL




Typical Failure on
Low Lubricity
Fluid

Innovative Fluid Power

Oilgear

WORN SADDLE BEARING

Note the
Material has
Delaminated



OVER PRESSURIZATION/SPIKES


Spike Relief Always Recommended

- Excessive swashblock face, cylinder to valve plate wear
- Pistons broken at necks
- Broken shaft where cylinder rides
- Broken tail shaft (dual)
- Control pin broken
- Cylinder cracked between kidneys
- Control O-ring, gasket failure (PVW)



Oilgear


EXCESSIVE WEAR ON CYLINDER FACE



Cracks
Would
Appear
Between
Kidneys


TORSIONAL FATIGUE:

Note Cone Shaped Failure



BENDING FATIGUE FAILURE

Note Straight Break




IMPROPER INLET CONDITIONS

Suction Strainer not Recommended

- CAVITATION ON VALVE PLATE FACE
- NOISE (MARBLE SOUND)

CAVITATION ON COMPRESSION BRIDGE

Oilgear




Innovative Fluid Power

CASE TO INLET DIFFERENTIAL

In General Differential Cannot Exceed 10 PSI


- SHOE EDGES ROUNDED
- SHOES LOOSE ON BALLS
- SWASHBLOCK WEAR, HALF MOON SHAPE
- EXCESSIVE WEAR ON BACK OF SHOE FLANGES
- SEAL RETAINER BENT

WHAT DOES CASE PRESSURE DO ?




30 PSI AT INLET, 0 PSI CASE

TROUBLE !!!!!



0 PSI INLET, 30 PSI CASE


STAGES OF DAMAGE DUE TO SHOE LIFT



3rd Stage
2nd Stage
1st Stage



Oilgear




**THE
FINAL
STAGE
OF
SHOE
LIFT**

Innovative Fluid Power

Oilgear

HALF MOON SHAPED MARKS




A Sure Sign
of Shoe Lift




Oilgear

ROLLED SHOES: THE TELL TALE OF SHOE LIFT



Innovative Fluid Power



Oilgear

**WEAR ON
SHOE
RETAINER
FROM
SHOE
FLANGES**

Innovative Fluid Power

The Oilgear logo is written in a bold, blue, sans-serif font. It is positioned in the upper right corner of the slide, partially overlapping a blue-tinted background image of an industrial control room.

Oilgear

BENT SEAL RETAINER



Innovative Fluid Power

MISCELLANEOUS

- **INPUT SHAFT BROKEN**
 - MISALIGNMENT
 - TORQUE REVERSAL
- **CONTROL INSTABILITY**
 - AIR
 - INCREASE CONTROL PISTON ORIFICE
- **PUMP VIBRATES**
 - MISALIGNMENT
 - COUPLING HALF'S TOUCHING

HELPFUL HINTS FOR ANALYZING BASKET CASES

- The last piece to fail will have the least amount of damage
- Try to piece together the broken parts. This may seem like a waste of time but many times you will observe things which can help you determine the original cause of failure.
- Get the history of events:
 - ▶ What recently changed ?
 - ▶ What was going on just prior to failure ?
 - ▶ How long was pump run ?
 - ▶ Talk to the operators

KEYS TO FAILURE ANALYSIS

- Don't go into a customer's problem with a preconceived idea about the cause
- Don't assume anything, verify everything
- Don't overlook the obvious